

RESOLUTION AUTHORIZING ENDORSEMENT OF  
APPLICATION FOR TREATMENT WORKS APPROVAL (TWA-1)

**Forest Trail Pump Station**

6 Forest Trail  
Block 41101, Lot 254  
Township of Denville

**WHEREAS**, an application for Treatment Works Approval has been submitted by the Township of Denville which proposes the replacement of four (4) pumps at the Forest Trail Pump Station, on Tax Block 41101, Lot 254, located at 6 Forest Trail, Denville, New Jersey for review by the Rockaway Valley Regional Sewerage Authority (RVRSA), which extension project is more particularly described in the Treatment Works Approvals Permit Application Form (TWA-1), attached hereto and made a part hereof; and

**WHEREAS**, the New Jersey Department of Environmental Protection (NJDEP) presently requires the certification of the 201 Sewerage Agency, as well as the certification of the owner of the sewerage treatment facility, and endorsement of WQM-003 Part A-2 for Treatment Works Approval within the sewer service area of the agency; and

**NOW, THEREFORE, BE IT RESOLVED** by the Rockaway Valley Regional Sewerage Authority as follows:

1. JoAnn Mondisini, Executive Director of the RVRSA is authorized and directed to execute the Treatment Works Approval (TWA-1 Application) Form WQM-003 entitled Endorsements at subsections A2-C subject to the following conditions:
  - A. That subsection C Certification by Wastewater Treatment Facility Owner shall not be executed, however, a notation shall be inserted to refer to an addendum attached which includes a revised certification which provides as follows:

I (we) certify that the treatment plant is currently complying with its conventional and non-conventional NJPDES permit requirements (see N.J.A.C. 7:14A-22.17 (b)-(d), flow percent removal and toxicity requirements excluded from this

certification) as determined by a rolling average of the three most recent monthly discharge monitoring reports that were required to be submitted to the Department as of this date, and based upon my (our) assessment of all information pertinent to this permit request, is anticipated to continue to do so with the additional flow from this project.

- B. That this approval explicitly excludes connection of vacant lot(s), which encroach upon any environmentally sensitive areas (ESA) pursuant to Special Grant Condition No. 4, federal project C340389-04-2, effective November 29, 1983.
- C. This approval is expressly conditioned upon compliance, by the Applicant, with any relevant provisions of the Highlands Preservation and Planning Act or any rules or regulations issued pursuant thereto, if any.
- D. That any connection from a non-domestic source is subject to the RVRSA's industrial pretreatment program regulations, as applicable. The applicant shall first obtain a clearance form the RVRSA's pretreatment program prior to seeking for obtaining the necessary permit(s) for connection to the RVRSA's local/regional conveyance system.
- E. That the qualified property owner shall obtain the necessary permit(s) for sewer connection(s) to the RVRSA system, in connection therewith and the requirements of other governmental entities having jurisdiction.
- F. That the sewer mainline and each of the building lateral to be installed in connection with the project shall be subject to inspection(s) by the RVRSA, if applicable.
- G. That this endorsement shall expire automatically unless the attached application is filed with the NJDEP within 60 days of the day of the adoption of this Resolution. Evidence of submission shall be submitted by the Applicant to RVRSA in order to satisfy this requirement.

- H. This approval is subject to compliance with revised Service Rules of the RVRSA, and the payment of the appropriate fees and/or charges of the RVRSA including, but not limited to those set forth at Section 4.03 (3) Revised Service Rules of the RVRSA, and payment of the appropriate fees of any other governmental authority having jurisdiction, as applicable.
- I. In the event that the allocation remains unconnected to the RVRSA System for longer than eighteen (18) months from the date of this resolution, then payments shall be made to the RVRSA representing the debt service and capital cost funded by the users for the prior year—calculated on the number of gallons per day allocated but unconnected, if applicable. Such payment shall be made each year until the allocated gallonage is connected or terminated.
- J. The approval of the use of NJDEP's gallonage determination is made under protest and for the sole purpose of approving the TWA-1 sewer extension application and shall not affect in any way gallonage allocated for RVRSA's planning purposes.

I hereby certify that this Resolution was adopted at a meeting of the Rockaway Valley Regional Sewerage Authority held on March 27, 2014

On motion of Glenn Corbett

Second by Joseph Lowell


And a Roll Call Vote as Follows:

Yeas: (6) Cegelka, Corbett, Lowell, Schorno, Secco and Vincitore

Nays: (0) None

Abstain: (1) Andes

Absent: (3) Guadagno, Recchia, Schaefer

  
Mary Roman  
Assistant Board Secretary

**FACT SHEET**  
**Forest Trail Pump Station - Denville**

**Action Request:** WQM-003 Part A-2 endorsement for Treatment Works Approval

**Project Location:** Township of Denville  
6 Forest Trail  
Block 41101, Lot 254

**Applicant:** Township of Denville  
1 St. Mary's Place  
Denville, NJ

**Project:** Replacement of four (4) pumps at pump station. Replace 5 hp & 7.5 hp pumps with 10 hp pumps and replace 2- 60 hp pumps with 20 hp pumps.

**Service Area:** The pump station services Denville as part of the RVRSA Service Area.

**Wetlands:** Not applicable. Work is being done within existing building.

**Gallorage (FC/FS):** Not applicable.

**Flow Metered at:** MC: DV

**Local Approval:** Township of Denville Resolution R-14-47, dated 2/19/14

**Ownership Disclosure Statement:** Not applicable.

**Engineer:** John Ruschke, PE  
Hatch Mott MacDonald  
Hampton, NJ  
908-730-6000