

RESOLUTION AUTHORIZING ENDORSEMENT OF
APPLICATIONS FOR TREATMENT WORKS APPROVAL (TWA-1)
**179 Cedar Lake East
and 181A Cedar Lake East
Township of Denville**
Block 61302, Lot 111 and Block 61302, Lot 112

WHEREAS, applications for Treatment Works Approval have been submitted by the Township of Denville (“Denville”) which propose the extension of the sanitary sewer to serve two existing residential structures at 179 Cedar Lake East, Block 61302, Lot 111 and 181A Cedar Lake East, Block 61302, Lot 112, Township of Denville, currently on septic systems, and which already serves an existing house (185 Cedar Lake East, Block 61302, Lot 110), for a total of three (3) connections. The project is more particularly described in the Treatment Works Approvals Permit Application Forms (TWA-1), attached hereto and made a part hereof; and

WHEREAS, it has been confirmed by the Morris County Planning & Development, on April 24, 2018, that, based on NJDEP approved Wastewater Management Plan maps, the area is within the approved Sewer Service Area served by the RVRSA; and

WHEREAS, the New Jersey Department of Environmental Protection (NJDEP) presently requires the certification of the 201 Sewerage Agency, as well as, the certification of the owner of the sewerage treatment facility, that its treatment system contains sufficient capacity to accept the additional flow, which would emanate from the sewer extension proposed in the said application; and

WHEREAS, pursuant to RVRSA’s planning estimates the gallonage required to service the proposed project is in the amount of 450 GPD; and

WHEREAS, the additional gallonage required to service the project pursuant to the calculation of the NJDEP is 225 GPD for 179 Cedar Lake East, Block 61302, Lot 112) and 300 GPD for 181A Cedar Lake East, Block 61302, Lot 112; and

WHEREAS, the Township of Denville is required to endorse the projects; which, it has done by Resolutions R-18-81 (179 Cedar Lake East, Block 61302, Lot 112) and R-18-82 (181A Cedar Lake East, Block 61302, Lot 112), both dated March 21, 2018; and

WHEREAS, RVRSA is desirous of facilitating Denville's applications for sewer service extensions.

NOW, THEREFORE, BE IT RESOLVED by the Rockaway Valley Regional Sewerage Authority as follows:

1. There shall be allocated from RVRSA's "First Come/First Serve" category, gallonage in the amount of 225 GPD for 179 Cedar Lake East, Block 61302, Lot 112 and 225 GPD for 181A Cedar Lake East, Block 61302, Lot 112, for a total of 450 GPD.
2. JoAnn Mondini, Executive Director of the RVRSA is authorized and directed to execute the Treatment Works Approval (TWA-1 Application) Forms WQM-003 entitled Endorsements at subsections C subject to the following conditions:
 - A. That subsection C Certification by Wastewater Treatment Facility Owner shall not be executed; however, a notation shall be inserted to refer to an addendum attached which includes a revised certification which provides as follows:

I (we) certify that the treatment plant is currently complying with its conventional and non-conventional NJPDES permit requirements (see N.J.A.C. 7:14A-22.17 (b)-(d), flow percent removal and toxicity requirements excluded from this certification) as determined by a rolling average of the three most recent monthly discharge monitoring reports that were required to be submitted to the Department as of this date, and based upon my (our) assessment of all information pertinent to this permit request, is anticipated to continue to do so with the additional flow from this project.
 - B. That this approval explicitly excludes connection of vacant lot(s), which encroach upon any environmentally sensitive areas (ESA) pursuant to Special Grant Condition No. 4, federal project C340389-04-2, effective November 29, 1983.
 - C. This approval is expressly conditioned upon compliance, by the Applicant, with any relevant provisions of the Highlands Preservation and Planning Act or any rules or regulations issued pursuant thereto, if any.

- D. That any connection from a non-domestic source is subject to the RVRSA's industrial pretreatment program regulations. The applicant shall first obtain a clearance form from the RVRSA's pretreatment program prior to seeking for obtaining the necessary permit(s) for connection to the RVRSA's local/regional conveyance system.
- E. That the property owners shall obtain the necessary permit(s) for sewer connection(s) to the RVRSA system, in connection therewith and the requirements of other governmental entities having jurisdiction, including obtaining a TWA-1 for the house already connected at 185 Cedar Lake East, Block 61302, Lot 110, Denville, or the property owner shall submit written documentation to the RVRSA evidencing that a TWA-1 is not required by law.
- F. That the sewer mainline and each of the building laterals to be installed in connection with the project shall be subject to inspection(s) by the RVRSA.
- G. That this endorsement shall expire automatically unless the attached application is filed with the NJDEP within 60 days of the day of the adoption of this Resolution. Evidence of submission shall be submitted by the Applicant to RVRSA in order to satisfy this requirement.
- H. This approval is subject to compliance with revised Service Rules of the RVRSA, and the payment of the appropriate fees and/or charges of the RVRSA including, but not limited to those set forth at Section 4.03 (3) Revised Service Rules of the RVRSA, and payment of the appropriate fees of any other governmental authority having jurisdiction.
- I. The approval of the use of NJDEP's gallonage determination is made under protest and for the sole purpose of approving the TWA-1 sewer extension application and shall not affect in any way gallonage allocated for RVRSA's planning purposes.
- J. In the event that a TWA-1 is required with respect to the connection of the residential dwelling at 185 Cedar Lake East, Block 61302, Lot 110, Denville, this

approval shall not constitute an approval, endorsement, or allowance to construct, operate, commence, build, modify, install, replace, expand or operate a treatment works for 185 Cedar Lake East, Block 61302, Lot 110, Denville, until a TWA-1 is obtained.

I hereby certify that this Resolution was adopted at a meeting of the Rockaway Valley Regional Sewerage Authority held on May 10, 2018.

On motion of Glenn Corbett

Second by John Cegelka


And a Roll Call Vote as Follows:

Yeas: (7) Andes, Cegelka, Corbett, Guadagno, Isselin, Rossi, Schorno

Nays: (0) None

Abstain: (1) Vincitore

Absent: (2) Lowell and Recchia


Michael Guadagno
Board Secretary

FACT SHEET
179 Cedar Lake East – Denville, NJ

Action Request: WQM-003 Part C Endorsement for Treatment Works Approval for connection of septic system

Project Location: Township of Denville
Block 61302, Lot 111

Applicant: James F and James G McIntosh
11 Watchtower Road, Denville, NJ 07834

Project: Replace existing septic system with a connection to the existing municipal sewer system.
Sewer extension of 385 LF for residential use.

Service Area: Property is verified to be in the RVRSA via e-mail from Virginia Michelin dated 4-24-18.

Wetlands: The project site contains no floodplains, wetlands, as per Engineer's Certification signed and sealed by Thomas F. Graham, P.E. dated April 27, 2018.

Gallorage (FC/FS): NJDEP criteria 225 gpd (2 Bedroom dwelling)
RVRSA gallonage 225 gpd

Flow Metered at: DV-1

Local Approval: Township of Denville Resolution R-18-81, dated 3/21/2018

Failed System Certification: N/A

Ownership Disclosure Statement: See Attached Dated 4-25-2018

Engineer: Thomas F. Graham, PE
Dykstra Walker Design Group
21 Bowling Green Parkway – Suite 204
Lake Hopatcong, NJ 07849
(973) 663-6540 ext 14

5/4/2018

FACT SHEET
181A Cedar Lake East – Denville, NJ

Action Request: WQM-003 Part C Endorsement for Treatment Works Approval for connection of septic system.

Project Location: Township of Denville
Block 61302, Lot 112

Applicant: James F McIntosh
11 Watchtower Road, Denville, NJ 07834

Project: Replace existing septic system with a connection to the existing municipal sewer system.
Sewer extension of 370 LF for residential use.

Service Area: Property is verified to be in the RVRSA via e-mail from Virginia Michelin dated 4-24-18.

Wetlands: The project site contains no floodplains, wetlands, or associated buffers, as per Engineer's Certification signed and sealed by Thomas F. Graham, P.E. dated April 27, 2018.

Gallage (FC/FS): NJDEP criteria 300 gpd (3 Bedroom dwelling)
RVRSA gallage 225 gpd

Flow Metered at: DV-1

Local Approval: Township of Denville Resolution R-18-82, dated 3/21/2018

Failed System Certification:
N/A

Ownership Disclosure Statement: See Attached Dated 4-25-2018

Engineer: Thomas F. Graham, PE
Dykstra Walker Design Group
21 Bowling Green Parkway – Suite 204
Lake Hopatcong, NJ 07849
(973) 663-6540 ext 14

5/4/2018