

RESOLUTION AUTHORIZING ENDORSEMENT OF
APPLICATION FOR TREATMENT WORKS APPROVAL (TWA-1)
100 Richboynton Road
Town of Dover
Block 606, Lot 18

WHEREAS, an application for Treatment Works Approval have been submitted by the Town of Dover (“Dover”) which proposes the construction and connection of 245 LF of 4 inch diameter PVC pipe along Richboynton Road, to serve an existing garage with office area. The building was previously sewerred via a force main that traversed an adjacent lot (under a building) to a sewer main on Route 15. This TWA is to install a new lateral that will extend the sewer along Richboynton Road and reconnect Block 606, Lot 18. The Project is more particularly described in the Treatment Works Approvals Permit Application Forms (TWA-1), attached hereto and made a part hereof; and

WHEREAS, based on NJDEP approved Wastewater Management Plan maps, the Project is within the approved Sewer Service Area served by the RVRSA; and

WHEREAS, the New Jersey Department of Environmental Protection (NJDEP) presently requires the certification of the 201 Sewerage Agency, as well as, the certification of the owner of the sewerage treatment facility, that its treatment system contains sufficient capacity to accept the additional flow, which would emanate from the sewer extension proposed in the said application; and

WHEREAS, pursuant to RVRSA’s planning estimates the gallonage required to service the proposed Project is in the amount of 200 GPD; and

WHEREAS, the gallonage required to service the proposed Project pursuant to the NJDEP is in the amount of 200 GPD; and

WHEREAS, the Town of Dover is required to endorse the Project; which, it has done by Resolution 68-2020, adopted February 11, 2020; and

WHEREAS, RVRSA is desirous of facilitating Dover's application for sewer service extension.

NOW, THEREFORE, BE IT RESOLVED by the Rockaway Valley Regional Sewerage Authority as follows:

1. There shall be allocated from RVRSA's "First Come/First Serve" category, gallonage in the amount of 0 GPD to serve an existing and currently connected building located on 100 Richboynton Road, Block 606, Lot 18, in the Town of Dover.
2. JoAnn Mondsinì, Executive Director of the RVRSA is authorized and directed to execute the Treatment Works Approval (TWA-1 Application) Forms WQM-003 entitled Endorsements at subsections C subject to the following conditions:
 - A. That subsection C Certification by Wastewater Treatment Facility Owner shall not be executed, however, a notation shall be inserted to refer to an addendum attached which includes a revised certification which provides as follows:

I (we) certify that the treatment plant is currently complying with its conventional and non-conventional NJPDES permit requirements (see N.J.A.C. 7:14A-22.17 (b)-(d), flow percent removal and toxicity requirements excluded from this certification) as determined by a rolling average of the three most recent monthly discharge monitoring reports that were required to be submitted to the Department as of this date, and based upon my (our) assessment of all information pertinent to this permit request, is anticipated to continue to do so with the additional flow from this project.
 - B. That this approval explicitly excludes connection of vacant lot(s), which encroach upon any environmentally sensitive areas (ESA) pursuant to Special Grant Condition No. 4, federal project C340389-04-2, effective November 29, 1983.
 - C. This approval is expressly conditioned upon compliance, by the Applicant, with any relevant provisions of the Highlands Preservation and Planning Act or any rules or regulations issued pursuant thereto, if any.
 - D. That any connection from a non-domestic source is subject to the RVRSA's industrial pretreatment program regulations. The applicant shall first obtain clearance from the RVRSA's pretreatment program prior to seeking the necessary permit(s) for connection to the RVRSA's local/regional conveyance system.

- E. That the qualified property owners shall obtain the necessary permit(s) for sewer connection(s) to the RVRSA system, in connection therewith and the requirements of other governmental entities having jurisdiction.
- F. That the sewer mainline and each of the building laterals to be installed in connection with the project shall be subject to inspection(s) by the RVRSA.
- G. That this endorsement shall expire automatically unless the attached application is filed with the NJDEP within 60 days of the day of the adoption of this Resolution. Evidence of submission shall be submitted by the Applicant to RVRSA in order to satisfy this requirement.
- H. This approval is subject to compliance with revised Service Rules of the RVRSA, and the payment of the appropriate fees and/or charges of the RVRSA including, but not limited to those set forth at Section 4.03 (3) Revised Service Rules of the RVRSA, and payment of the appropriate fees of any other governmental authority having jurisdiction.
- I. The approval of the use of NJDEP's gallonage determination is made under protest and for the sole purpose of approving the TWA-1 sewer extension application and shall not affect in any way gallonage allocated for RVRSA's planning purposes.

I hereby certify that this Resolution was adopted at a meeting of the Rockaway Valley Regional Sewerage Authority held on May 14, 2020.

On motion of Glenn Corbett

Second by Thomas Andes

And a Roll Call Vote as Follows:


Yeas: (10) Andes, Cegelka, Corbett, Guadagno, Isselin, Farrell, Recchia, Rossi, Schorno, Zuppa

Nays: (0)

Resolution 20-050

Abstain: (0)

Absent: (0)


Michael Guadagno
Board Secretary

FACT SHEET
100 RichBoynton Road – Town of Dover

Action Request: WQM-003 Part C Endorsement for Treatment Works Approval

Project Location: Town of Dover
100 Richboynton Road, Town of Dover
Block 606, Lot 18

Property Owner: Estate of Dimitrios Paliatsas
Mr. George Paliatsas
11 Cattano Avenue
Apartment #514
Morristown, NJ 07960

Project: This building was previously sewered via a force main that traversed an adjacent lot to a sewer main on Route 15. This TWA is to install a new lateral that will extend the sewer along Richboynton Road with approximately 245 linear feet of 4- inch diameter PVC pipe.

Service Area: The property is located within the RVRSA service area as confirmed by Robert Bocchino, P.E., RVRSA Manager of Engineering

Wetlands: Not on RVRSA list of environmentally sensitive areas.

Gallorage (FC/FS): NJDEP criteria 200 gpd
RVRSA gallorage 200 gpd

Flow Metered at: D-1 (Verified by RVRSA Trunk Line Manager)

Local Approval: Town of Dover Resolution 68-2020

Ownership Disclosure Statement: Pending

Engineer: John E. Gribbini, PE
Jaman Engineering Associates
320 Route 10 West
Randolph, NJ 07869
973-366-6277